



Allen&Hoshall

713 South Pear Orchard Road, Suite 100
Ridgeland, Mississippi 39157
Office 601.977.8993
Fax 601.977.8924
www.allenhoshall.com

30 October 2017

**The Mayor and Aldermen of
The City of Vicksburg, Mississippi**
P.O. Box 150
Vicksburg, Mississippi 39180

**Re: 2017 Water Treatment Plant Monitoring and Control Equipment
Vicksburg, Mississippi**

Gentlemen:

Enclosed for approval is Contract Amendment No. 3 with Control Systems, Inc. in connection with the referenced project. This Amendment adds grounding grids at ten of the existing wells which do not have adequate grounding. We recommend that this Amendment be approved. After approval please return two executed copies to us.

If you have any questions or need additional information, please let me know.

Sincerely,

Allen & Hoshall

Edwin K. Dedeaux, PE
Principal

ededeaux@allenhoshall.com

pc: Garnet Van Norman, w/Enclosure

Enclosures



Allen & Hoshall

713 South Pear Orchard Road, Suite 100
Ridgeland, Mississippi 39157
Office 601.977.8993
Fax 601.977.8924
www.allenhoshall.com

CONTRACT AMENDMENT

NO. 3

Project: 2017 Water Treatment Plant Monitoring and Control Equipment Date: 30 October 2017
Owner: City of Vicksburg, Mississippi
Contractor: Control Systems, Inc.

The contract, dated 10 July 2017, between the above listed parties, is hereby amended as set forth below. Description of and reason for amendment:

The addition of ground grids at existing Well Nos. 2, 3, 4, 5, 6, 7, 8, 9, 11, and 12 is needed. These sites do not have the minimum grounding resistance currently required by the National Electrical Code.

Information from Control Systems, Inc. is attached.

Contract Amount is Amended as Follows:

Present Contract Amount	<u>\$211,601.00</u>
Net Change in Contract	<u>\$13,750.00</u>
Amended Contract Amount	<u>\$225,351.00</u>

Contract Time is Amended as Follows:

Present Completion Date	<u>11 January 2018</u>
Net Change-No. of Days	<u>0</u>
Amended Completion Date	<u>11 January 2018</u>

Recommended by Edin K. Oediger
Allen & Hoshall
Approved by Control Systems, Inc. - Richard Sparks Jr.
Contractor
Approved by _____
Owner



CONTROL SYSTEMS, INC.

909 Quinn Street • Jackson, Mississippi 39202
P.O. Box 4852 • Jackson, Mississippi 39296-4852
Phone 601.355.8594 • FAX 601.355.8774

QUOTATION

October 17, 2017

TO: Allen & Hoshall – Ed Dedeaux

This document contains 1 page(s).

RE: Change Order Requests #3 and #4 – Vicksburg, MS
CSI Quote Ref #50579_CO3_CO4

COMMENTS:

We are pleased to offer the following quotation on the above mentioned project.

<u>Item</u>	<u>Qty</u>	<u>Description</u>	<u>Price</u>
1.	3	Change Order Request #3 Elevated Tank Transmitters ETPLT elevated tank pressure/level transducer to be installed in existing enclosure.	\$4,875.00 \$1,625.00 NE
2.	16	Change Order Request #4 Well Site Ground Grids Test existing ground. Furnish and install ground grid at each well site.	\$22,000.00 \$1,375.00 NE

TOTAL NET \$26,875.00

Payment Terms: NET 30 DAYS

Richard

Richard Sparks

E-MAIL - RichardS@controlsysinc.com
S:\QUOTES\50579_CO3_CO4.wpd

A 20% order cancellation fee will be enforced if cancelled after submittals are complete.
Applicable taxes are NOT included.
As a supplier, CSI does NOT allow retainage against invoices.

This quotation is good for 60 days.
Page 1 of 1