



Allen & Hoshall

1675 Lakeland Drive, Suite 100
Jackson, Mississippi 39216
Office 601.977.8993
Fax 601.949.4344
www.allenhoshall.com

5 January 2018

MM
OF
AM

JAN 09 2018

The Mayor and Alderman of
The City of Vicksburg, Mississippi
P. O. Box 150
Vicksburg, Mississippi 39180

**Re: 2017 Water Treatment Plant Monitoring and Control Equipment
Vicksburg, Mississippi**

Gentlemen:

Enclosed for approval is Contract Amendment No. 4 with Control Systems, Inc. in connection with the referenced project. This Amendment replaces inoperable pressure switches at eleven wells and replaces the inoperable mechanical portions of flow meters at nine wells. We recommend that this amendment be approved. After approval, please return two executed copies to us.

Let me know if you have any questions or need additional information.

Sincerely,

Allen & Hoshall

Edwin K. Dedeaux, PE
Principal
601-214-6000 cell

ededeaux@allenhoshall.com

pc: Garnet Van Norman, w/Enclosure

Enclosures



1675 Lakeland Drive, Suite 207
Jackson, Mississippi 39216
Office 601.977.8993
Fax 601.949.4344
www.allenhoshall.com

CONTRACT AMENDMENT

NO. 4

Project: 2017 Water Treatment Plant Monitoring and Control Equipment Date: 4 January 2018

Owner: City of Vicksburg, Mississippi

Contractor: Control Systems, Inc.

The contract, dated 10 July 2017, between the above listed parties, is hereby amended as set forth below. Description of and reason for amendment:

The replacement of inoperable positive pump pressure switches for Well Nos. 1, 3, 5, 6, 7, 11, 12, 13, 16, 17, and 18.

The replacement of the inoperable the mechanical portions of flow meters for Well Nos. 1, 2, 3, 4, 6, 8, 9, 11, and 12.

Information from Control Systems, Inc. is attached.

Contract Amount is Amended as Follows:

Present Contract Amount	\$225,351.00
-------------------------	--------------

Net Change in Contract	\$13,689.00
------------------------	-------------

Amended Contract Amount	\$239,040.00
-------------------------	--------------

Contract Time is Amended as Follows:

Present Completion Date 11 January 2018

Net Change-No. of Days	30
------------------------	----

Amended Completion Date 10 February 2018

Recommended by

Allen & Hoshal

Approved by

Contractor

Approved by _____

Owner



CONTROL SYSTEMS, INC.

909 Quinn Street • Jackson, Mississippi 39202
P.O. Box 4852 • Jackson, Mississippi 39296-4852
Phone 601.355.8594 • FAX 601.355.8774

QUOTATION

January 4, 2018

TO: Allen & Hoshall – Ed Dedeaux

This document contains 1 page(s).

RE: Change Order Request #5 – Vicksburg, MS
CSI Quote Ref #50579_CO5

COMMENTS:

We are pleased to offer the following quotation on the above mentioned project.

<u>Item</u>	<u>Qty</u>	<u>Description</u>		<u>Price</u>
1.	11	Positive Pump Pressure Switches furnish and install each positive pump pressure switch	\$441.00 NE	\$4,851.00
2.	9	Mechanical Portion of Flowmeters furnish and install mechanical portion of flowmeters	\$982.00 NE	\$8,838.00
			TOTAL NET	\$13,689.00

Richard

Richard Sparks

E-MAIL - RichardS@controlsysinc.com
S:\QUOTES\50579_CO5.wpd

A 20% order cancellation fee will be enforced if cancelled after submittals are complete.
Applicable taxes are NOT included.
As a supplier, CSI does NOT allow retainage against invoices.

This quotation is good for 60 days.
Page 1 of 1